APPENI

SANITARY SEW
ANI
SANITARY SEWEI

Before you Dig - Pennsylvania Act 187, Under
Requires You Call Pennsylvani

1. General – Sanitary sewer lateral shall incl test tee, clean-outs, running trap with fres connection to the building drain. Down-s drains, or french drains shall not be connec

2. Size - Residential - 4" minimum diameter 1/4" per foot. Non-Residential - 6" mi minimum slope of 1/8" per foot.

3. Materials – The sanitary sewer lateral shall case of 6" pipe that may be SDR 35 or Sc same size as the sanitary sewer lateral wit shall be installed no less than two (2) and of the outside wall. The pipe as it exits the depth of 48". Vent pipes and clean-outs cartpaths, walkways or other finished surfa Authority. The vent cap shall be installed into the sanitary sewer lateral.

   Food preparation establishments and oth Authority shall install grease traps of a styl in food preparation areas of these establishr

4. Clean-Outs and Directional Changes - Cle curved fitting, riser pipe and a watertigh directional changes greater than 45 degrees exceptions.

5. Adapters - Approved adapters as manufactu may be used to connect pipe joints, reduce the running trap. All adapters shall be sta steel clamps or must be encased in concrete.

6. Installation - Before digging the trench, t connection and the building drain. Trench have uniform slope as near as possible at ri