APPENDIX II

SANITARY SEWER LA
AND
SANITARY SEWER CONI

Before you Dig - Pennsylvania Act 187, Underground
Requires You Call Pennsylvania One (

1. General – Sanitary sewer lateral shall include co
test tee, clean-outs, running trap with fresh air v
connection to the building drain. Down-spouts, 1
drains, or french drains shall not be connected to t

2. Size - Residential - 4" minimum diameter pipe t
1/4" per foot. Non-Residential - 6" minimum
minimum slope of 1/8" per foot.

3. Materials – The sanitary sewer lateral shall be Sch
case of 6" pipe that may be SDR 35 or Schedule
same size as the sanitary sewer lateral with a ver
shall be installed no less than two (2) and no mor
of the outside wall. The pipe as it exits the buildin
depth of 48". Vent pipes and clean-outs are not
cartpaths, walkways or other finished surface areas
Authority. The vent cap shall be installed 6" abov
into the sanitary sewer lateral.

   Food preparation establishments and other esta
Authority shall install grease traps of a style and s
in food preparation areas of these establishments sh

4. Clean-Outs and Directional Changes - Clean-outs
curved fitting, riser pipe and a watertight cap a
directional changes greater than 45 degrees. No 9
exceptions.

5. Adapters - Approved adapters as manufactured by
may be used to connect pipe joints, reduce 6" pipe
the running trap. All adapters shall be stainless s
steel clamps or must be encased in concrete.

6. Installation - Before digging the trench, the insta
connection and the building drain. Trench width s
have uniform slope as near as possible at right ang