APPENDIX II

SANITARY SEWER LATERAI
AND
SANITARY SEWER CONNECTI

Before you Dig - Pennsylvania Act 187, Underground Utility I
Requires You Call Pennsylvania One Call 1-8(

1. General – Sanitary sewer lateral shall include connection test tee, clean-outs, running trap with fresh air vent, a g connection to the building drain. Down-spouts, rain con drains, or french drains shall not be connected to the sanita

2. Size - Residential - 4" minimum diameter pipe that is in 1/4" per foot. Non-Residential - 6" minimum diamet minimum slope of 1/8" per foot.

3. Materials – The sanitary sewer lateral shall be Schedule 4(case of 6" pipe that may be SDR 35 or Schedule 40 solid same size as the sanitary sewer lateral with a vent pipe a shall be installed no less than two (2) and no more than f of the outside wall. The pipe as it exits the building wall s depth of 48". Vent pipes and clean-outs are not permitt cartpaths, walkways or other finished surface areas unless] Authority. The vent cap shall be installed 6" above grade into the sanitary sewer lateral.

   Food preparation establishments and other establishm(Authority shall install grease traps of a style and size acce in food preparation areas of these establishments shall also

4. Clean-Outs and Directional Changes - Clean-outs, consist curved fitting, riser pipe and a watertight cap are requ directional changes greater than 45 degrees. No 90 degre(exceptions.

5. Adapters - Approved adapters as manufactured by Fernco may be used to connect pipe joints, reduce 6" pipe to 4" an the running trap. All adapters shall be stainless steel shi(steel clamps or must be encased in concrete.

6. Installation - Before digging the trench, the installer sho connection and the building drain. Trench width shall be have uniform slope as near as possible at right angles to th