APPENDIX II

SANITARY SEWER LATE
AND
SANITARY SEWER CONNE

Before you Dig - Pennsylvania Act 187, Underground Uti
Requires You Call Pennsylvania One Call

1. General – Sanitary sewer lateral shall include conne test tee, clean-outs, running trap with fresh air vent connection to the building drain. Down-spouts, rain drains, or french drains shall not be connected to the s

2. Size - Residential - 4" minimum diameter pipe that 1/4" per foot. Non-Residential - 6" minimum di minimum slope of 1/8" per foot.

3. Materials – The sanitary sewer lateral shall be Schedu case of 6" pipe that may be SDR 35 or Schedule 40 same size as the sanitary sewer lateral with a vent p shall be installed no less than two (2) and no more th of the outside wall. The pipe as it exits the building v depth of 48". Vent pipes and clean-outs are not pe cartpaths, walkways or other finished surface areas un Authority. The vent cap shall be installed 6" above g into the sanitary sewer lateral.

   Food preparation establishments and other establi Authority shall install grease traps of a style and size in food preparation areas of these establishments shall

4. Clean-Outs and Directional Changes - Clean-outs, cc curved fitting, riser pipe and a watertight cap are directional changes greater than 45 degrees. No 90 d exceptions.

5. Adapters - Approved adapters as manufactured by Fe may be used to connect pipe joints, reduce 6" pipe to 4 the running trap. All adapters shall be stainless steel steel clamps or must be encased in concrete.

6. Installation - Before digging the trench, the installer connection and the building drain. Trench width shal have uniform slope as near as possible at right angles