APPENDIX II

SANITARY SEWER LATERAL AND SANITARY SEWER CONNECTION

Before you Dig - Pennsylvania Act 187, Underground Utility Line
Requires You Call Pennsylvania One Call 1-800-2

1. General – Sanitary sewer lateral shall include connection to t test tee, clean-outs, running trap with fresh air vent, a greas connection to the building drain. Down-spouts, rain conduct drains, or french drains shall not be connected to the sanitary s

2. Size - Residential - 4" minimum diameter pipe that is install 1/4" per foot. Non-Residential - 6" minimum diameter p minimum slope of 1/8" per foot.

3. Materials – The sanitary sewer lateral shall be Schedule 40 sol case of 6" pipe that may be SDR 35 or Schedule 40 solid core same size as the sanitary sewer lateral with a vent pipe and p shall be installed no less than two (2) and no more than five (of the outside wall. The pipe as it exits the building wall shall depth of 48". Vent pipes and clean-outs are not permitted t cartpaths, walkways or other finished surface areas unless prior Authority. The vent cap shall be installed 6" above grade to p into the sanitary sewer lateral.

   Food preparation establishments and other establishments Authority shall install grease traps of a style and size acceptab in food preparation areas of these establishments shall also have

4. Clean-Outs and Directional Changes - Clean-outs, consisting curved fitting, riser pipe and a watertight cap are required directional changes greater than 45 degrees. No 90 degree be exceptions.

5. Adapters - Approved adapters as manufactured by Fernco, Inc may be used to connect pipe joints, reduce 6" pipe to 4" and co the running trap. All adapters shall be stainless steel shielde steel clamps or must be encased in concrete.

6. Installation - Before digging the trench, the installer should connection and the building drain. Trench width shall be kept have uniform slope as near as possible at right angles to the str