APPENDIX II

SANITARY SEWER LATERAL
AND
SANITARY SEWER CONNECTION

Before you Dig - Pennsylvania Act 187, Underground Utility Line Protection Law of 1996
Requires You Call Pennsylvania One Call 1-800-242-1776

1. General – Sanitary sewer lateral shall include connection to the public sewer, sight te test tee, clean-outs, running trap with fresh air vent, a grease trap where required, a connection to the building drain. Down-spouts, rain conductors, driveway drains, ar drains, or french drains shall not be connected to the sanitary sewer lateral.

2. Size - Residential - 4" minimum diameter pipe that is installed to a minimum slope 1/4" per foot. Non-Residential - 6" minimum diameter pipe that is installed to minimum slope of 1/8" per foot.

3. Materials – The sanitary sewer lateral shall be Schedule 40 solid core PVC, except in th case of 6" pipe that may be SDR 35 or Schedule 40 solid core PVC. A running trap th same size as the sanitary sewer lateral with a vent pipe and plastic mushroom vent ca shall be installed no less than two (2) and no more than five (5) feet from the outer fac of the outside wall. The pipe as it exits the building wall shall be installed at a minimu depth of 48". Vent pipes and clean-outs are not permitted to be located in driveway cartpaths, walkways or other finished surface areas unless prior approval is granted by th Authority. The vent cap shall be installed 6" above grade to prevent the inflow of wat into the sanitary sewer lateral.

   Food preparation establishments and other establishments at the discretion of th Authority shall install grease traps of a style and size acceptable to the Authority. Sink in food preparation areas of these establishments shall also have under-sink grease traps.

4. Clean-Outs and Directional Changes - Clean-outs, consisting of a wye branch fitting, curved fitting, riser pipe and a watertight cap are required every 100 feet or at a directional changes greater than 45 degrees. No 90 degree bends shall be permitted. N exceptions.

5. Adapters - Approved adapters as manufactured by Fernco, Inc., or approved equivalen may be used to connect pipe joints, reduce 6" pipe to 4" and connect the building drain t the running trap. All adapters shall be stainless steel shielded couplings with stainles steel clamps or must be encased in concrete.

6. Installation - Before digging the trench, the installer should expose the sanitary sewe connection and the building drain. Trench width shall be kept to a minimum width an have uniform slope as near as possible at right angles to the street. Excavate all trenche



CONDENSED INSTALLATION SPECIFICATIONS

SANITARY SEWER LATERAL AND SANITARY SEWER SERVICE CONNECTIONS SHALL BE INSTALLED BY SKILLED WORKMEN AT THE COST OF THE CUSTOMER IN ACCORDANCE WITH APPENDIX II OF THE RULES AND REGULATIONS DETAILED SPECIFICATIONS OF THE AUTHORITY.

NOTE:

1. ALL PIPE SHALL BE 4" SCH. 40 SOLID CORE PVC OR 6" SCH. 40 SOLID CORE PVC OR SDR-35. SLOPE SHALL BE MIN. 1/4" PER FOOT FOR 4" LINE AND 1/8" PER FOOT SLOPE FOR 6" LINE.
2. CLEANOUTS ARE REQUIRED EVERY 100 FEET AND AT ALL DIRECTIONAL CHANGES GREATER THAN 45 DEGREES.



SEWER SERVICE LINE PIPE:
NOTE: ALL PVC MUST BE SOLID CORE

MATERIAL	ASTM SPECIFICATIONS JOINT			ASTM SPEC.
4" PVC	D-1875	SCH-40	SOLVENT WELD	D-2564
6" PVC	D-3034	SDR-35	ELASTOMERIC	D-3212

ROSTRAVER TOWNSHIP SEWAGE AUTHORITY 1744 Rostraver Road Belle Vernon, PA 15012		SERVICE CONNECTION TO SANITARY SEWER LATERAL FROM A NEW INSTALLATION
Not to scale	April 2013	Standard Detail SD-028